

JUNE 2016 OUTAGE SUMMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
06/01/16	80	1	690	Bird in cut out	Belfry	OH	80
06/03/16	375	1	300	Bad URD	Roberts	URD	375
06/06/16	65	18	790	Consumer hit line	Roberts	OH	1170
06/07/16	285	3	300	URD fault	Edg/From	URD	855
06/07/16	90	12	690	Birds / C phase blew	Belfry	OH	1080
06/07/16	60	1	unknown	High-side fuse blown	Nye	OH	60
06/09/16	130	1	300	Neutral ground loop broke	Absarokee	OH	130
06/11/16	90	3	300	Fuse open on 3 phase	Columbus	URD	270
06/14/16	150	9	300	Bad insulator	Reed Point	OH	1350
06/20/16	10	30	790	Cut into URD primary prematurely	Columbus	URD	300
06/24/16	100	1	300	Neutral tie wore in two (holding tri-plex together)	Nye	OH	100
06/24/16	100	62	490	Tree through line	Absarokee	OH	6200
06/29/16	245	4	300	Bad URD primary	Red Lodge	URD	980
06/29/16	60	35	490	Tree	Columbus	OH	2100
06/30/16	75	1	unknown	Blown arrestor	Absarokee	OH	75
TOTALS	1915	182					15125

RUS CAUSE CODE KEY	
090	Weather
110	Planned Outage/Maintenance
300	Other Material/Equipment Fault
490	Trees
500	Transformer
690	Animals
790	Public Caused
Other	Other

Absarokee	3
Belfry	2
Columbus	3
E Rosebud	0
Edg/From	1
Luther	0
Nye	2
Red Lodge	1
Reed Pnt	1
Roberts	2