

**NOVEMBER 2016 OUTAGE SUMMARY**

| Date          | Duration (Min) | Number of Customers Affected | RUS Cause Code | Cause of Service Interruption (RUS Designation 1730A-119) | Substation | OH/ URD | Customer Minutes of Interruption |
|---------------|----------------|------------------------------|----------------|---|------------|---------|----------------------------------|
| 11/04/16      | 120            | 4                            | Unknown        | Blown fuse  | Belfry     | OH      | 480                              |
| 11/05/16      | 120            | 2                            | Unknown        | Two blown fuses   | Red Lodge  | OH      | 240                              |
| 11/12/16      | 75             | 1                            | 490            | Line burned down  | Columbus   | OH      | 75                               |
| 11/17/16      | 85             | 9                            | 090            | Snow loading  | Edg/From   | OH      | 765                              |
| 11/17/16      | 60             | 1                            | 090            | Snow loading  | Edg/From   | OH      | 60                               |
| 11/17/16      | 85             | 43                           | 090            | Snow loading  | Edg/From   | OH      | 3655                             |
| 11/17/16      | 60             | 1                            | 090            | Snow loading  | Absarokee  | OH      | 60                               |
| 11/17/16      | 60             | 1                            | 090            | Snow loading  | Red Lodge  | OH      | 60                               |
| 11/24/16      | 120            | 7                            | 790            | Wire had been shot  | Roberts    | OH      | 840                              |
| 11/28/16      | 30             | 6                            | 110            | Planned outage  | Red Lodge  | OH      | 180                              |
| 11/30/16      | 120            | 1                            | 110            | Planned outage  | Absarokee  | OH      | 120                              |
| <b>TOTALS</b> | <b>935</b>     | <b>76</b>                    |                |   |            |         | <b>6535</b>                      |

| RUS CAUSE CODE KEY |                                |
|--------------------|--------------------------------|
| 090                | Weather                        |
| 110                | Planned Outage/Maintenance     |
| 300                | Other Material/Equipment Fault |
| 490                | Trees                          |
| 500                | Transformer                    |
| 690                | Animals                        |
| 790                | Public Caused                  |
| Other              | Other                          |

|                  |          |
|------------------|----------|
| <b>Absarokee</b> | <b>2</b> |
| <b>Belfry</b>    | <b>1</b> |
| <b>Columbus</b>  | <b>1</b> |
| <b>E Rosebud</b> | <b>0</b> |
| <b>Edg/From</b>  | <b>3</b> |
| <b>Luther</b>    | <b>0</b> |
| <b>Nye</b>       | <b>0</b> |
| <b>Red Lodge</b> | <b>3</b> |
| <b>Reed Pnt</b>  | <b>0</b> |
| <b>Roberts</b>   | <b>1</b> |