

OCTOBER 2016 OUTAGE SUMMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
10/03/16	85	1	unknown	Blown fuse	Belfry	OH	85
10/03/16	60	3	unknown	Blown fuse	Roberts	OH	180
10/03/16	130	1	300	Faulted URD cable	Edg/From	URD	130
10/04/16	160	18	690	Dead bird found on metal cut out	Reed Point	OH	2880
10/04/16	135	15	490	Tree through line	Red Lodge	OH	2025
10/05/16	70	7	690	Blown fuse/Birds	Belfry	OH	490
10/06/16	75	12	690	Blown fuse/Birds	Belfry	OH	900
10/06/16	30	17	690	Raccoon on riser pole	Columbus	OH	510
10/11/16	125	6	490	Tree through line	Columbus	OH	750
10/12/16	95	25	490	Tree through line	Roberts	OH	2375
10/14/16	120	5	490	Tree through line	Red Lodge	OH	600
10/14/16	135	103	490	Tree through line	Absarokee	OH	13905
10/14/16	630	24	490	Multiple trees through lines	Red Lodge	OH	15120
10/14/16	140	10	490	Tree through line	Nye	OH	1400
10/14/16	130	4	090	High winds/re-fused tap	Nye	OH	520
10/14/16	150	8	490	Tree through line	E Rosebud	OH	1200
10/14/16	90	1	490	Tree through line	Nye	OH	90
10/14/16	90	15	490	Tree through line	Nye	OH	1350
10/14/16	165	550	000	NW Energy lost 50 K.V. (Nye Sub down)	Nye	OH/URD	90750
10/17/16	45	30	unknown	Blown fuse	Roberts	OH	1350
10/18/16	90	260	000	NW Energy had one phase down	Luther	OH	23400
10/21/16	15	25	110	Replaced damaged primary ped	Columbus	OH	375
10/24/16	75	1	790	Faulted consumer secondary wire	Edg/From	URD	75
10/26/16	120	59	790	Contractor /Dig-in	Columbus	URD	7080
10/29/16	75	1	790	Customer's main breaker in house	Reed Point	OH	75
TOTALS	3035	1201					167615

RUS CAUSE CODE KEY	
090	Weather
110	Planned Outage/Maintenance
300	Other Material/Equipment Fault
490	Trees
500	Transformer
690	Animals
790	Public Caused
Other	Other

Absarokee	1
Belfry	3
Columbus	4
E Rosebud	1
Edg/From	2
Luther	1
Nye	5
Red Lodge	3
Reed Pnt	2
Roberts	3