

APRIL 2016 OUTAGE SUMMARY

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
04/01/16	30	4	110	Planned Outage for new service	Columbus	URD	120
04/03/16	270	57	300	URD fault	Nye	OH	15390
04/05/16	135	70	490	Tree blew through line	Absarokee	OH	9450
04/07/16	90	50	000	Planned outage for NW Energy	Reed Point	OH	4500
04/08/16	35	12	300	Pole tipped over	Reed Point	OH	420
04/17/16	210	180	unknown	Either 10 amp OCR or arrestor on OCR	Nye	OH	37800
04/18/16	165	310	300	Two bells tracking	Absarokee	OH	51150
04/18/16	110	20	690	Crows nest	Belfry	OH	2200
04/22/16	155	1	110	Planned outage to change out A5 transformer pole	Roberts	OH	155
04/23/16	240	105	000	NW Energy dropped static wire on our 3 ph line	Belfry	OH	25200
04/27/16	510	2	unknown	refused step down transformer	Columbus	OH	1020
TOTALS	1950	811					147405

RUS CAUSE CODE KEY	
090	Weather
110	Planned Outage/Maintenance
300	Other Material/Equipment Fault
490	Trees
500	Transformer
690	Animals
790	Public Caused

Absarokee	2
Belfry	2
Columbus	2
East Rosebud	0
Edgar/From	0
Luther	0
Nye	2
Red Lodge	0
Reed Point	2
Roberts	1