

**FEBRUARY 2016 OUTAGE SUMMARY**

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
02/13/16	85	1	500	Transformer tripped	Absarokee	OH	85
02/18/16	60	4	090	Wind broke load side jumper	Red Lodge	OH	240
02/24/16	90	11	690	Owl caught between phases	Belfry	OH	990
02/29/16	90	6	300	Broken jumper	Absarokee	OH	540
<b>TOTALS</b>	<b>325</b>	<b>22</b>					<b>1855</b>

RUS CAUSE CODE KEY	
090	Weather
110	Planned Outage/Maintenance
300	Other Material/Equipment Fault
490	Trees
500	Transformer
690	Animals
790	Public Caused
Other	Other

Absarokee	2
Belfry	1
East Rosebud	0
Edgar/From	0
Luther	0
Nye	0
Red Lodge	1
Reed Point	0
Roberts	0