

March 2016 Outage Summary

Date	Duration (Min)	Number of Customers Affected	RUS Cause Code	Cause of Service Interruption (RUS Designation 1730A-119)	Substation	OH/ URD	Customer Minutes of Interruption
03/02/16	140	30	300	Stranded conductor	Columbus	OH	140
03/05/16	120	7	300	Broken Jumper	Belfry	OH	840
03/18/16	75	3	300	Blown fuse	Belfry	OH	225
03/24/16	45	760	790	Consumer cut tree into line	Belfry	OH	34200
03/25/16	95	10	690	Crows next on transformer	Belfry	OH	950
03/25/16	30	685	110	Planned outage	Roberts	OH	20550
03/29/16	120	3	unknown	Re-fused cut out	Edgar/From	OH	360
03/31/16	5	67	490	Trees on line	Red Lodge	OH	335
03/31/16	150	14	300	Bad pole top glass	Belfry	OH	2100
TOTALS	780	1579					59700

RUS CAUSE CODE KEY	
090	Weather
110	Planned Outage/Maintenance
300	Other Material/Equipment Fault
490	Trees
500	Transformer
690	Animals
790	Public Caused
Other	Other

Absarokee	0
Belfry	5
Columbus	1
East Rosebud	0
Edgar/From	1
Luther	0
Nye	0
Red Lodge	1
Reed Point	0
Roberts	1